

## Current Status of Power Line Track Crossings as on 17.10.2023

Pending on Party Account			Under Process in Railways		
Approved for Execution w/o Energization			Case dropped		
S. N.	Case File No.	Section	TP/km	Supply Voltage (kV)	Remarks
1	63-Elect/X-ing/UG/2017-915	SSA-BTI	241/3-4	11	Case dropped due not submitting the reply from party for 2 years.
2	63-Elect/X-ing/OH/2021-994	LGH-PLC	112/0-1	765	Case is to be sent for DRM approval.
3	63-Elect/X-ing/OH/2021-995	LGH-PLC	107/9-108/1	765	Party has not submitted clarification on SBC and tower foundation.
4	63-Elect/X-ing/OH/2022-1016	RE-SDLP	157/0-1	132	This crossing is lying in STNL station yard. Letter is written to party on 19.06.2023 for submitting the SBC report of location.
5	63-Elect/X-ing/OH/2023-1024	RE-BNW	2/6-2/7	765	Work approval granted without energisation on 12.10.2023.
6	63-Elect/X-ing/OH/2023-1025	RE-BNW	36/0-1	765	Case is with S&T department for signature on drawing plan.
7	63-Elect/X-ing/OH/2023-1026	RE-SDLP	122/2-3	765	Work approval granted without energisation on 29.09.2023.
8	63-Elect/X-ing/OH/2023-1027	HMH-SOG	103/7-8	11	Demand note and FDR submission letter written to party on 22.09.2023.
9	63-Elect/X-ing/OH/2023-1039	HMH-SDLP	171/3-4	132	Letter is written to XEN Ratangarh on 10.07.2023 for submitting the proposal as per 90° angle of crossing. Reminder-I is written to XEN Ratangarh on 06.09.2023 in this regard.
10	63-Elect/X-ing/OH/2023-1040	RTGH-BKN	316/9-10	220	Letter is written to XEN Ratangarh on 10.07.2023 for submitting the proposal as per 90° angle of crossing. Reminder-I is written to XEN Ratangarh on 06.09.2023 in this regard.
11	63-Elect/X-ing/OH/2023-1041	RTGH-SRDR	3/8-3/9	132	Letter is written to XEN Ratangarh on 10.07.2023 for submitting the proposal as per 90° angle of crossing. Reminder-I is written to XEN Ratangarh on 06.09.2023 in this regard.